

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE		PAGE 1 OF 1 PAGES
2. AMENDMENT/MODIFICATION NO. R0001		3. EFFECTIVE DATE 03/31/04		4. REQUISITION/PURCHASE REQ. NO.	
5. PROJECT NO. (If applicable)					
6. ISSUED BY CODE		J4P0000		7. ADMINISTERED BY (If other than Item 6) CODE DACA85	
US ARMY ENGINEER DISTRICT, AK CEPOA-CT (W911KB) PO BOX 6898 ELMENDORF AFB, AK 99506-6898 CRYSTAL LABRECQUE 907-753-5578		US ARMY ENGINEER DISTRICT, AK CEPOA-CO-NAO PO BOX 35066 (BLDG 3025) FAIRBANKS, ALASKA 99703-0066			
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(X)	9A. AMENDMENT OF SOLICITATION NO.
				X	W911KB-04-R-0022
				9B. DATED (SEE ITEM 11) 03/26/04	
				10A. MODIFICATION OF CONTRACT/ORDER NO.	
10B. DATED (SEE ITEM 13)					
CODE 089C4		FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☒ is extended, ☐ is not extended.

Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning 0 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. Accounting and Appropriation Data (If required)

PROJECT TITLE AND LOCATION: Construct Type III Hydrant Fuel System/Expand/Repair Aircraft Ramp, Eielson AFB, Alaska

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

(X)	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc). SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☒ is not, ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

PROPOSAL DUE DATE IS EXTENDED TO 27 APR 04, 2:00 PM, local time, at the US Army Corps of Engineers-Alaska District, 2204 Third St, Elmendorf AFB, Alaska

NOTICE TO OFFERORS: PLEASE MARK OUTSIDE OF ENVELOPE IN WHICH BID IS SUBMITTED TO SHOW AMENDMENTS RECEIVED. YOU ARE REQUIRED TO ACKNOWLEDGE RECEIPT OF THIS AMENDMENT ON THE REVERSE SIDE OF STANDARD FORM 1442.

IMPORTANT NOTE: Keep in mind that the base is still under tight security measures and access to non-DOD personnel is limited or restricted and requires extra time to process through the Boniface Gate.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF SIGNER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		BY (Signature of Contracting Officer)	

SOLICITATION, OFFER, AND AWARD <i>(Construction, Alteration, or Repair)</i>	1. SOLICITATION NUMBER AM#1 DACA 85-02-R-0032 W911KB-04-R-0022.AM#1	2. TYPE OF SOLICITATION <input type="checkbox"/> SEALED BID (IFB) <input checked="" type="checkbox"/> NEGOTIATED (RFP)	3. DATE ISSUED 03/26/04	PAGE OF PAGES
	IMPORTANT - The "offer" section on the reverse must be fully completed by the offeror.			
4. CONTRACT NUMBER	5. REQUISITION/PURCHASE REQUEST NUMBER	6. PROJECT NUMBER		
7. ISSUED BY US ARMY ENGINEER DISTRICT, ALASKA CEPOA-CT (W911KB) PO BOX 6898 ANCHORAGE, AK 99506-6898	CODE W911KB	8. ADDRESS OFFER TO US Army Engineer District, Alaska 2204 3rd Street Elmendorf AFB, Alaska 99506 Mailing: PO Box 6898 Anchorage, AK 99506-6898		
9. FOR INFORMATION CALL	A. NAME Crystal Labrecque		B. TELEPHONE NUMBER (include area code) (NO COLLECT CALLS) (907)753-5578/ email crystal.d.labrecque@usace.army.mil	

SOLICITATION

NOTE: In sealed bid solicitations "offer" and "offeror" mean "bid" and "bidder".

10. THE GOVERNMENT REQUIRES PERFORMANCE OF THE WORK DESCRIBED IN THESE DOCUMENTS (Title, identifying number, date):

NAICS: 237120

PROJECT TITLE/LOCATION: Construct Type III Hydrant Fuel System/Expand/Repair Aircraft Ramp, Eielson AFB, Alaska

FULL AND OPEN COMPETITION

DESCRIPTION OF WORK: This will be a fully designed project with options. The solicitation will be a request for proposal. This project will include installation of a 2,400 GPM Standard Type III Aircraft Hydrant Fueling System with 16 hydrant pit/outlets, two above ground 10,000 BBL operating tanks, pump house, 2 position truck fill stand, HSV checkout facility, pantograph storage facility and an emergency generator and an Aircraft Parking Apron with 16 parking positions for C-17 aircraft with concrete parking aprons, taxi-ways, security lighting, taxi-way edge lighting, striping and miscellaneous repairs of existing taxiways. The project will include demolition of three existing Type I Hydrant Fueling Systems including 3 pump-houses, underground storage tanks, fuel piping and pits. Responders are advised that the requirements may be delayed, cancelled or revised at any time during the solicitation, selection, evaluation, negotiation, and/or final award process based on decisions related to DOD changes and disposition of the Armed Services. THIS SOLICITATION WILL BE ISSUED USING ELECTRONIC BID SETS (EBS) AND PROVIDED ON OUR WEBSITE AT NO CHARGE.

<https://ebs.poa.usace.army.mil/AdvertisedSolicitations.asp>

****Contract award subject to availability of funds**

11. The Contractor shall begin performance within <u>10</u> calendar days and complete it within _____ calendar days after receiving	
<input type="checkbox"/> award, <input checked="" type="checkbox"/> notice to proceed. This performance period is <input checked="" type="checkbox"/> mandatory, <input type="checkbox"/> negotiable. (See <u>SCR-1 (also calendar days)</u> .)	
12A. THE CONTRACTOR MUST FURNISH ANY REQUIRED PERFORMANCE PAYMENT BONDS? (If "YES," indicate within how many calendar days after award in Item 12B.)	12B. CALENDAR DAYS
<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	10
13. ADDITIONAL SOLICITATION REQUIREMENTS:	
** SEE SECTION 00100, Part III, General Requirements A. Sealed offers in original and _____ copies to perform the work required are due at the place specified in Item 8 by <u>2:00 PM</u> (hour) local time <u>AM#1..2726 Apr 2004 ..AM#1</u> (date). If this is a sealed bid solicitation, offers will be publicly opened at that time. Sealed envelopes containing offers shall be marked to show the offeror's name and address, the solicitation number, and the date and time offers are due.	
B. An offer guarantee <input checked="" type="checkbox"/> is, <input type="checkbox"/> is not required.	
C. All offers are subject to the (1) work requirements, and (2) other provisions and clauses incorporated in the solicitation in full text or by reference.	
D. Offers providing less than <u>60</u> calendar days for Government acceptance after the date offers are due will not be considered and will be rejected.	

Solicitation No. W911KB-04-R-0022

Construct Type III Hydrant Fuel System/Expand/Repair Aircraft Ramp,
Eielson AFB, Alaska

Amendment No. R0001

NARRATIVE CHANGE:

1. Proposal due date is changed from 26 Apr 04 to 27 Apr 04.
2. Section 15060 PIPE, Manual Valves, And Fittings, Fueling System,
paragraph 3.7.7 Grade, change 2ND sentence to:

'Maintain gradient to within \pm 1/4-inch over the entire length of pipe, however in no case shall local slope of the piping be less than 0.2%.'